Meteorology 433

Thermometry Spring 2022


General

- Temperature impacts every day life.
- Errors of 2-3 °C are not uncommon in many networks.
 - Bank thermometers or Car thermometers.
- Errors of this magnitude are generally acceptable to the general public.
- Errors of just 1 °C have been shown to be the deciding factor between no storms initiated, and intense storms in mesoscale models (Crook, 1996)
- Errors as small as 0.2 °C can change prediction of a global climate model, depending on initial conditions (DeFelice, 1998).


Categories

- Temperature sensors are categorized according to the physical principle they use.
- Mechanical (thermo-expansion)
 - Direct indicating instruments
 - Mercury or Alcohol
 - Bi-metallics
- Electronic (thermo-electric)
 - Thermocouples.
 - Electrical resistance.
 - Thermistors.
 - LM35 or similar integrated circuit device.
 - Designed to work with data loggers.
- Sensing can be passive or remote.

Mechanical Sensors







Thermocouple


- Junction of two dissimilar metals
- Seebeck effect: when the temperature of the two junctions of two dissimilar metals are at different temperatures, a voltage develops between them.
 - Thomas (1821)
- By measuring the voltage difference between the two junctions, the difference in temperature between the junctions can be calculated.
- Alternately, if the temperature of one junction is know and the voltage difference is measured, then the temperature of the second junction can be calculated.
- Want more details? See five "laws of thermocouple behavior" starting on page 67.

Advantages/disadvantages

- Advantages
 - Rugged
 - Reliable
 - Inexpensive
- Disadvantages
 - Very low voltage output (~ 40 μV / °C) amplifier needed.
 - Slight non-linearity
 - Need to be calibrated
- Thermopile: a number of thermocouple connected in series.
 - All junctions are exposed to the same temperature
 - Voltages add up allowing for a large voltage.

What is a linear sensor?

What can you say about the static sensitivity of these sensors?



Electrical Resistance Sensors

Resistance varies as a function of temperature.

- Conductive sensors ≡ Resistance Temperature Detectors
 - RTD's

Thermistors

RTD's

- Platinum is most common
 - Stable, Resists corrosion, High melting point
 - Simple resistance-temperature relationship
- $R_T = R_o (1 + aT + bT^2)$
 - Sufficient accuracy from -50 °C to 50 °C.
 - $-R_0$ = resistance at 0 °C.
 - Coefficients a and b depend on purity of platinum.
- What if b is small?
- Resistance is converted to a voltage.




Thermistors


- Temperature sensitive semiconductors
 - Typically metallic oxides.
- Large and significantly non-linear temperature sensitivity.
- Transfer equation.
 - Most have decreasing sensitivity with increasing temperature.
- Despite their nonlinearity, thermistors are used in a wide variety of applications.
- High resistance (compared to RTD's)
 - Lead wires

Thermistors




Integrated Circuit Sensors









RTD Problem

Self-heating.

- Measurement of resistance typically involves the passage of electrical current.
 - Heats RTD.

Exposure

 What processes or types of exposure errors is a temperature sensor (without a shelter) exposed to?

Conduction

Convection

Radiation

Reducing Exposure

- Completely isolate the instrument from the atmosphere.
- Conduction: non-heat conductive mounting bracket.
- Convection: Shelter that isolates it from the air flow.
- Radiation: Highly reflective shelter.
- Sensor still needs to be in contact with what you are measuring, i.e., the atmosphere.

Gill Plate Aspiration



FIGURE 3-3. 41003-5 Radiation Shield Mounted to Tripod Mast

Compact Fan Aspiration



No win situation

 If snow is present (or other highly reflective ground surface), the exposure errors will increase.

 Exposure errors are always excluded from laboratory calibrations, so manufacturer performance specifications are not necessarily a good prediction of actual field performance.